



06701-9383-0  
info@ibs-scherer.de

## Overview

# IBS Exhaust System Type KA

Product number: 2120017





## Description

Mandatory for technical ventilation according to BGR 180 (ZH 1/562) for IBS Parts Cleaning Device Type K, if solvents are used with a flashing point between 40°C and 55°C. The exhaust fan blows possibly developing aerosols outwards.

## Product information

<b>Connected load:</b>	0.14 KW
<b>Connection:</b>	230 V, 50 Hz
<b>Insulation class:</b>	B
<b>Protection class:</b>	IP 54